

Product certificate

The company

TEUFELBESCHLAG GmbH

hereby certifies that the product

Sliding door System PRAKTICA

Art. No. 4-012

has been tested on the basis of **EN 1527** by means of in-house production control and long-time testing as a heavy suspended sliding door.

The product meets the following demands:

Max. panel weight	150 kg
Maximum glass thickness in mm	12
Number of cycles	> 100 000
Functional capability	Class 6
Initial friction	Class 3

Classification key according to EN 1527:

1	2	3	4	5	6	7	8	9
-	6	3	0	-	0	-	1	3

When using Praktica Art. No. 4-012 a minimum panel width of 1000 mm has to be ensured.

Tuerkenfeld, 17.07.2019

TEUFELBESCHLAG GmbH
Am Brand 8
82299 Tuerkenfeld
Germany